

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No. F.6 DFS/MS/School/2021/SZ/ 519

Dated: 23/7/2021

FIRE SAFETY CERTIFICATE

Certified that the Kendriya Vidyalaya A.A.I Rangpuri, New Delhi 110037 comprised of ground plus two upper floors in one block and ground plus one upper floor in second block owned/occupied by Kendriya Vidyalaya A.A.I was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS.School/2014/SZ/1171 Dt. 11/09/2014. The said premises was re-inspected by officer concerned of this department on 14/07/2021 in presence of Sh. P.P Yadav of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular dated 01/03/2011 and that the building is fit for occupancy class "Educational Building Group - B" with effect from 23/7/2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 23/7/2021 at New Delhi by


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to:-

1. The Principal, Kendriya Vidyalaya A.A.I Rangpuri, New Delhi 110037
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.
3. Dy Director (Education) Kendriya Vidyalaya Sangathan, Delhi Region, JNU Camp New Mehrauli Road, New Delhi -110067

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form J [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."